NOTE: DO NOT SCALE, FIELD DIMENSIONS TO TAKE PRECEDENCE.

ONE LINE DIAGRAM



EXISTING STORAGE

EXISTING FURNITURE STORE

NOTE:
Existing general lighting in bathrooms has an efficiency of at least 40 lumens per watt (florescent).

EXISTING BATHROOM WOMEN

EXISTING UTILITY/ MECHANICAL ROOM

EXISTING BATHROOM MEN

EXISTING HALL TO BATHROOMS

EXISTING AVAILABLE SPACE

EXISTING COVERED SIDEWALK

NEW HALL TO BATHROOMS

EXISTING BACK/ DELIVERY ZONE

EXISTING DELIVERY HALL

NOTE: Existing Lighting

New WH 40 Gal. 6385

EXISTING ROOM ELECTRIC MAIN SWITCH BOARD

NEW FREEZER

NEW FREEZER/COOLER WALK IN

NEW DISPLEY W/DOORS

NEW MEAT MARKET

NEW MEAT MARKET

CEILING LINE BREAK DN 4"

CEILING LINE BREAK DN 12"

NEW REGISTER

NEW REGISTER COUNTER

NEW PACKAGING COUNTER

NEW MEAT SAW 54"x20"

NEW CUTTING TABLE 36"x120"

NEW SLICER

NEW FLIP-UP COUNTER

NEW MEAT CASE 35 1/2"x96"

NEW MEAT CASE 35 1/2"x96"

NEW PRODUCE CASE

NEW PRODUCE CASE

NEW SODA CASE

NEW SODA CASE

NEW SODA CASE

6104, 6104A EXISTING ELECTRICAL PANEL 100/3ø 4 W, 120 V FLUSH MOUNT

EXISTING LIGHTED SIGN BOX SEE SIGN PERMIT FOR DETAILS

Exterior Lights Are Not Controlled From Meat Market's Panel

13'-1" PREP AREA

4"

10'-0" PREP AREA

36'-2" CUSTOMER AREA

MOVE TO NEW LOCATION

EXISTING CERAMIC STORE

ELECTRICAL PLAN
1/4"=1'-0"

Electrical Plan Notes

1. Provide general lighting having an efficiency of at least 40 lumens per watt (florescent).
2. Light fixtures in tub or shower enclosures shall be labeled "suitable for damp locations".
4. Smoke detectors shall be powered by 110V current with battery backup.
5. Owner to locate specialized outlets & jacks.
6. Provide a weatherproof GFCI electrical receptacle within 25' of AC unit (per UMC 509).
7. All electrical receptacles shall be @ 18" height from the finish floor, unless otherwise noted.
8. All incandescent lighting fixtures recessed into insulated areas shall be approved for zero-clearance insulation cover (I.C.) per the 1992 mandatory energy requirements.

ELECTRICAL SYMBOLS

- Duplex Receptacle Outlet
- Duplex Receptacle w/Cover
- 220 Receptacle
- Light Fixture
- Junction Box
- Exhaust Fan w/Fluorescent Light
- Recessed Light
- Smoke Detector
- Fluorescent Light Fixture
- Thermostat
- Ground Fault Circuit Interrupt
- Weatherproof Outlet
- Single Pole Switch
- Three-Way Switch
- Four-Way Switch
- Telephone

BUILDING DATA:

- 120/240 SINGLE PHASE
- "ROMEX" WIRE TYPICAL
- 15 AMP RECEPTACLE
- "GFI" RECEPTACLES PROVIDED (where applicable)

LEGEND
E – EXISTING
N – NEW

No.	Revision/Issue	Date

Firm Name:
TAYLOR DESIGN AND DRAFTING SERVICES
P. O. Box 905, Rocklin, CA 95677.
KATHLEEN TAYLOR Tel: (916) 624-1649 Fax: (916) 624-1910

Project Name and Address:
Retail Space Remodel For:
YOUR COMPANY
Address
City, CA
Tel: (916) 555-5555.

ELECTRICAL PLAN

File: AR9N6054A3
Date: 11/01/99
Scale: 1/4"=1'-0"
Sheet: 3 Of 4

All drawings on this sheet are copyright by TAYLOR Design and Drafting Services. Any reproduction of these drawings without the written permission of TAYLOR DD Srvs. is prohibited.